

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7270-1532:102

Page 1 of 1

CATEGORY: Heat Detectors

LISTEE: Thorn Security Ltd., Security House, The Summit, Hanworth Rd.,
Sunbury-on-Thames, Middlesex TW6 5DB, England
Contact: *Paul Mattern (978) 731-8542 Fax (978) 731-8881

DESIGN: Model MD912 electronic heat detector. Refer to listee's data sheet for additional detailed product description, electrical rating and operational considerations.

RATING: 135° F fixed temperature/rate of rise and 200° F fixed temperature

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as heat detector for use with Models M612/912 or 4B base (CSFM Listing No. 7300-1532:106) and separately listed compatible fire alarm control units.

*Revised 06-12-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 17, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager